



# City of Austin

Founded by Congress, Republic of Texas, 1839

Municipal Building, Eighth at Colorado, P.O. Box 1088, Austin, Texas 78767 Telephone 512/499-1111

May 3, 1991

Mr. Charles S. Cox, Sr.  
President & C.E.O.  
Verde Environmental, Inc.  
DBA: Verde Research and Development  
7309 Schnieder  
Houston, TX 77093

RE: Verde Product "Micro-Blaze" Product Acceptability Test

Dear Mr. Cox:

The Industrial Waste Procedures Manual includes a procedure which prohibits the use of hot water, enzymes, bacteria, chemicals, or other agents or devices for the purpose of causing the contents of a pretreatment device to be discharged into the sanitary sewer of the City of Austin unless the additive agent is tested and passes the City's product acceptability test.

Verde Environmental, Inc. has recently tested its product (Micro-Blaze) to verify compliance with the City's Industrial Waste Ordinance and procedures, i.e. that the product will not cause the pass through of greases and oils through a grease interceptor.

The results of the tests performed on Micro-Blaze under the criteria set forth in the Procedures Manual show that Micro-Blaze did not cause the grease and oil in the interceptor tested to pass through. The results of this test show that the use of Micro-Blaze under these conditions does not cause a violation of the Industrial Waste Ordinance.

Since Micro-Blaze is the only product tested, no other product manufactured or marketed by Verde Environmental, Inc. is covered by the previous statement.

This letter is not an endorsement of the product Micro-Blaze nor should it be used as such.

Sincerely,



Antonio M. Canales  
Industrial Waste Specialist II  
Industrial Waste Control Division  
Water and Wastewater Utility

XC: IW Files