



**METRO WASTEWATER
RECLAMATION DISTRICT**

6450 York Street - Denver, Colorado 80229-7499
(303) 286-3000 Telefax (303) 286-3030

Richard J. Plastino, Chairman of the Board
Robert J. Werner, Chairman Pro Tem
Richard N. Walker, Secretary
Martin E. Flahive, Treasurer

Robert W. Hito District Manager

November 21, 1996

Mr. Roger Lundberg
Verde Environmental, Inc.
9643 Timber Hawk Circle #22
Highlands Ranch, Colorado 80126

Dear Mr. Lundberg:

The Metro District has reviewed the information provided concerning the product Micro-Blaze Out. If the product is used at the manufacturer's recommended dosage levels, it appears it is acceptable for discharge to the sanitary sewer system with the restrictions noted below.

The product must be used at the recommended dosage, contain only nonpathogenic bacteria and the discharge must comply with all District Rules and Regulations (copy enclosed). Failure to allow complete digestion or treatment of wastewater may cause oil and grease, Total Petroleum Hydrocarbon (TPH), BTEX, or explosion hazard problems or violations.

The Metro District provides wastewater transmission and treatment services to 55 local governments in the Denver area. Although the District has determined the product to be acceptable to discharge, PERMISSION MUST BE OBTAINED FROM EACH GOVERNMENTAL ENTITY RESPONSIBLE FOR THE LOCAL COLLECTION SYSTEM.

Please contact me at the Metro District offices if you have any questions about the District's service area, or any other questions.

Sincerely,

Theresa A. Pfeifer
Industrial Waste Coordinator

TAP/tap/jm
N:\Letters\TAP\Micrblz3.doc

Enclosure

c: Mr. George Garramone, Rocky Mountain Fire Academy